



Minnesota Department of Transportation

Office of Bridges and Structures
Mail Stop 610
3485 Hadley Avenue North
Oakdale MN 55128-3307

Office Tel: 651/366-4485
Fax:651/366-4509

August 28, 2007

Joe Eull
3187 LaBeaux Avenue N. E.
St Michael, MN 55376

Jack Bergmann
Redi-Rock International
05481 South US 31
Charlevoix, Michigan 49720

Subject: Redi-Rock Retaining Wall Systems Pre-qualification

Dear Mr. Bergmann:

Mn/DOT has reviewed your company's "Redi-Rock Gravity Wall System" and "Redi-Rock Gravity Wall System with Earth Reinforcement" submittals. Your products meet Mn/DOT's pre-qualification requirements and Redi-Rock Gravity Wall System and Redi-Rock Gravity Wall System with Earth Reinforcement will be added to Mn/DOT's appropriate wall pre-qualification list along with other pre-qualified products. The Redi-Rock Gravity Wall System is approved for heights up to 8 ft while Redi-Rock Gravity Wall System with Earth Reinforcement is approved for heights up to 12 ft. The pre-qualification applies only to the Eull's Manufacturing Co. plant.

Please note that the pre-qualification of the wall systems shall not be regarded as final design acceptance. Each project will require the submittal of a project specific design.

If you have any questions or comments, please feel free to call me at 651-366-4484.

Thank you.

Sincerely,

A handwritten signature in black ink, appearing to read "Manjula".

Manjula Louis
Structural Standards Engineer
CC: K. Obeidat
SWC
James Lilly