



Minnesota Department of Transportation

Bridges Office

Mail Stop 610
3485 Hadley Avenue North
Oakdale MN 55128-3307

Office Tel: 651/366-4485
Fax: 651/366-4509

April 22, 2011

Mr. Kevin Eull
Eull's Manufacturing Co., Inc.
3187 LaBeaux Avenue N. E.
St. Michael, MN 55376

Subject: Redi Rock International Phase III submittal

Dear Mr. Eull:

Thank you for your comprehensive submittals on Redi Rock Wall with Earth Reinforcement Phase III. Mn/DOT has reviewed the submittal and it meets the Mn/DOT's pre-qualification requirements and will be added to Mn/DOT's Pre-Qualified Prefabricated Modular Block Wall with earth reinforcement (PMBW) list (as phase III prequalified for wall heights up to 20' height with 2' embedment) along with other pre-qualified products.

Please note that on Mn/DOT projects Eull's Redi-Rock will supply the contractor with the complete wall system including all components and that Eull's will notify Mn/DOT prior to starting wall design if the engineering firm is other than the firm listed in this submittal. Also note that the pre-qualification of the wall systems shall not be regarded as final design acceptance and that Eull's understands that failure of any of the wall components including the facing units, soil reinforcement or engineering design to meet the use restrictions in the executive summary of the submittal report or other requirements of the submittal or Mn/DOT specifications may result in removal of the Eull's Redi-Rock Reinforced Soil Wall System from the Mn/DOT Pre-qualified Products List. Each project will require the submittal of a project specific design.

If you have any questions or comments, please feel free to call me at 651-366-4485.

Sincerely,

A handwritten signature in black ink, appearing to read "Khalid Obeidat".

Khalid Obeidat
Structural Wall Engineer

CC: Ryan Berg
SWC